

## ADDENDUM #1

### HSE Report University of British Columbia, Okanagan Health and Safety Committee February 2011

#### 1. Upcoming Training

- AED/CPR training – March 15
- 1<sup>st</sup> Aid Practical Training – March 15

#### 2. Accident/Incident Report

- Slippery conditions across campus due to ice and snow (10 reported incidents this year)
- 1/13/11: SCI Evacuation due to smoke from burning vial caps which were being heated in an oven in SCI 127
- 2/4/11: Washdown water spill in FIP 379b
- 2/14/11: Ethylene glycol leak in FIP 377

#### 3. Events

- Fire Drills – January 11-13 (report attached)
- KFD building fire inspections – January 19-20

#### Upcoming Events

- none

#### 4. Statistics (January 1, 2011 to January 31, 2011):

##### First Aid Statistics:

Total staff reports (not including contractors) =	4
a. Sports & recreational injuries	0
b. Work-related (sprain, strain, cut, contusion, bruise)	2
c. Internal & other	1
d. Non-work related (sprains, strains, cuts, contusions)	1

##### WCB Claims:

Total Claims =	2
Healthcare only	1
Time loss & Healthcare	1
Pending decision	0

##### Ergonomics Report:

Total	2
Prevention	1
Follow up	1
Return to Work	0

# January 2011 Emergency Drill Report

## Arts - 7 min

1. Art 179, fire door not latching (Facilities Management)

## Administration 7 min

1. Bell at IT entrance not working (Facilities Management)
2. Cannot hear bells in server room (Facilities Management)
3. Server room door propped open (Emergency Director)
4. Auditorium door propped open (Emergency Director)
5. Bell in IT office not working (Facilities Management)

## Science- 5min

1. Fire door by 322 not closing properly (Facilities Management)
2. 396,204,126 and 105 doors left open (Emergency Director)
3. Need to recruit Emergency Director (HSE)

## Fipke- 5min

1. Handicapped person left unattended on third floor (Emergency Director)
2. Fire door by 2<sup>nd</sup> floor elevator not closing properly (Facilities Management)
3. Cannot hear bell at 150 (Facilities Management)
4. Doors left open at 245,239 and 250 (Emergency Director)

## U-House

Tested, not occupied

## Gym- 7min

1. Refusal to evacuate (HSE)

## UNC- 9min

## Fine Arts- 7min

1. Multiple doors left open (Emergency Director)

## Library- 8min

## Portables - 5min

1. Doors left open (Emergency Director)

## **Residence Buildings**

### Valhalla-Evac time 6min

### Kalamalka-Evac time 7min

### Nicola-Evac time 7min

Cassiar-Evac time 6min

Similkameen-Evac time 6min

Monashee-Evac time 7min

**Upper Cascades**-Evac time approximately 6min per building

**Lower Cascades**-Evac time approximately 6 min per building